

INTERIOR ALTERATIONS

**MCGEE MIDDLE SCHOOL
BLAST CLASSROOM
899 NORTON ROAD
BERLIN, CT**

TOWN OF BERLIN BID NO.: 2019-019

REQUESTS FOR INFORMATION

1. **Question:** Drawings A10.1 and A10.2 show ledge and toe kick grilles. Please confirm if Section 123200 is to provide them. We can provide all new per the Raymon Donco specs.

Answer: Allocations of the procurement and installations of the scope and relevant products between Sub-contractors is part of the means and methods of the General Contractor.

2. **Question:** Please confirm if locks are required on this casework and locations (ie- all cabinets).

Answer: All new casework doors and drawers are to have keyed locks. All locks to be keyed the same.

3. **Question:** Please confirm if removable cabinet backs are required in the base cabinets in front of the fin-tube radiation for access to controls. If required, please confirm detail size and location(s).

Answer: Provide access doors, per specification 08 31 13 – Access Doors, in all locations of valves or controls that require maintenance access. Coordinate required sizes and locations in field with existing conditions.

4. **Question:** Please confirm if any foil back insulation is required behind the casework for protection.

Answer: No.

5. **Question:** Please confirm interiors including shelves are to be white melamine per the specs or match the exterior color per the details highlighted on A10.1 attached. There are no open or exposed cabinets shown.

Answer: White melamine finish on all faces of the cabinet interior shelving will be acceptable.

6. **Question:** Please confirm if FSC and/or if AWI Custom or Premium grade casework is required.

Answer: Yes.

END OF ADDENDUM NO. 2