

FIRE ALARM UPGRADE

**HUBBARD ELEMENTARY SCHOOL
139 GROVE STREET
EAST BERLIN, CT**

APRIL 8, 2021 PRE-BID CONFERENCE

- 1 - See attached Pre-Bid Conference sign-in sheets.

GENERAL

- 1 - The demo note #10 on Drawing FAD1.00A says: "All Locations Where Existing Devices Have Been Removed Shall be Primed and Painted Two (2) Coats of Finish Paint to Match Surrounding Areas". Most of these locations are on glazed block will Blank Stainless steel plates be ok? Please advise.

Yes, stainless steel plates are acceptable at these locations.

- 2 - Spec: 284600 - Section: 1.4 System Description Sub Section C.14.C Speaker Circuits shall have 20% space capacity for future expansion or increased power output requirements. Drawing FA6.00 Fire Alarm General Notes Provide notification appliance circuit equipment to support layout plus 25%. Question: Which reserve percentage should be followed?

Provide 25% future capacity as indicated per the drawings.

TOWN COMMENTS

- 1 - Town permit fees are waived.
- 2 - The Town will not accept submissions by e-mail or fax. The Town Hall will remain closed to the public. It is strongly recommended bidders mail, UPS or FedEx bids. If bids will be brought in person, please call Maryssa Tsolis @ 860-828-7048 and she will meet your representative outside to accept the bid.

ATTACHMENTS

April 8, 2021 Pre-Bid Conference Sign-In Sheets

END OF ADDENDUM NO. 1

